

Inspection Certificate

Pressure transmitter					
Model		Pressure Range	(0~10) bar		
Accuracy	0.5% FS	Serial Number	250461465		
Output	(4~20)mA	Inspection Date	April 24, 2025		
Inspection condition					
Supply	24 VDC	Room temperature	20°C ± 2°C	Humidity	≤ 80%RH
Check Data					
Standard value(bar)	Measured value (mA)		LED display ()		
0	4.005				
2.5	8.014				
5.0	12.014				
7.5	16.016				
10.0	20.020				
Check Result					
Non-linearity	+0.13% FS	Repeatability	0.03% FS	Hysteresis	0.03% FS

Electrical connection

Two-Conductor 4 to 20 mA

