

**GRIFFIN AIR SYSTEMS LIMITED**

12 North Avenue  
 Clydebank Business Park,  
 Clydebank  
 Glasgow  
 G81 2QP

Tel: 0141 951 4424  
 Fax: 0141 951 4425  
 E-Mail: info@gas4air.co.uk  
 Web Site: www.gas4air.co.uk

**AIR QUALITY/BREATHING AIR CHECKLIST**

<b>Equip No:</b>	4420	<b>Inspect No:</b>	21018
<b>Make/Model:</b>	Shako / UCFR-UCMF-UCMFK	<b>Job No:</b>	10505
<b>Serial No:</b>		<b>Contact:</b>	
<b>Cust Equip No:</b>		<b>Inspected:</b>	27/06/2023
<b>Meter:</b>		<b>Printed:</b>	27/06/2023

<b>Site:</b>	MML MARINE LTD 60 WAVERLEY STREET COATBRIDGE ML5 2BE
--------------	---

Items to Inspect	Result	Comments
<b>SERVICE CHECK LISTS</b>		
AIR QUALITY TEST	PASS	
BREATHING AIR TEST	PASS	
AMBIENT TEMPERATURE	READING	19.4
PRESSURE BAR	READING	7.3
OXYGEN PERCENTAGE	READING	20.76
CARBON DIOXIDE PPM	READING	72
CARBON MONOXIDE PPM	READING	2.9
OIL RESULT	PASS	
FLOW RATE LTR/MIN	N/A	
DEWPOINT	OK	

**General Comments**

test point at new UCFR-UCMF-UCMFK breathing air filter regulator

Service carried out by: Engineer Name: Craig Liddell

Signature:

Customer Name: Gary

Signature: